

sect. 80 0710175 rev. 2014/09/27


XM500 I/O Module

The XM500 Module is a configurable Input/Output (I/O) module designed to bring analog and digital inputs and output onto the SAE J1939 CAN. The XM500 configuration tool provides a user-friendly interface allowing the user to create or change the configuration used on the XM500 module.


Your application may require monitoring of other information which may not be provided by the OEM engine or transmission electronic control unit (ECU), such as fuel level, hydraulic oil pressure or a low engine coolant level switch. The XM500 is ideally suited to bring the additional information you need onto the J1939 CAN bus and can be configured to broadcast fault codes and activate digital outputs per input condition such as fuel level low, hydraulic oil temperature high, etc. Because the XM500 broadcasts information using the J1939 standard protocol, the information can be displayed using standard J1939 display modules, such as the PowerView[®] 101.



Dimensions and Connections



Diagram



In order to consistently bring you the highest quality, full-featured products, we reserve the right to change our specifications and designs at any time. MURPHY products and the Murphy logo are registered and/or common law trademarks of Enovation Controls, LLC. This document, including textual matter and illustrations, is copyright protected by Enovation Controls, LLC, with all rights reserved. (c) 2016 Enovation Controls, LLC. A copy of the warranty may be viewed or printed by going to http://murphybyenovationcontrols.com/warranty.

[36.00]

Specifications

Electrical

Power Input: 8 to 28VDC Communication Ports: CAN J1939 Operating Temperature: -40° F to 185° F (-40° C to 85° C) Digital Inputs: 4 - Ground or battery positive activation Digital Outputs*: 2 Sinking (500 mA) Product Weight: 10 ounces Shipping Weight: 12 ounces Shipping Dimensions: 4" x 6" x 2"

*(Outputs are NOT reverse polarity protected. Damage will occur if B+ is connected to the outputs. Damage incurred from improper installation is not covered under the Murphy limited warranty policy.)

Thermocouple Input¹: Type K and Type J

Analog Inputs²:

1 - Battery Supply Voltage (dedicated)

7 - Configurable as 0-5 VDC, 4-20 mA, resistive senders³ or used as an additional digital input


Speed Sensing Input: Magnetic pickup (2 to 120 VAC RMS from 30 to 10,000 Hz)

¹When the thermocouple input is used, only 5 resistive, 4-20 mA, or 0-5 VDC can be used instead of 7.

²Analog inputs can be exchanged for digital inputs (battery ground activation only) for a total of 11 digital inputs.

³Other resistive senders can be supported. Contact Murphy's Industrial Panel Division for programming charges.

Connector Pins



Con	Connector A (gray)			
Pin	Description		1	
1	Digital IN 2		ŀ	
2	Digital IN 3		2	
3	Analog 6		;	
4	Analog 4		4	
5	Analog 2		ļ	
6	J & K Type -		(
7	J & K Type +		-	
8	Analog 1		1	
9	Analog 3		ļ	
10	Analog 5			
11	Analog 7		•	
12	Digital IN 1			

Connector B (black)				
Pin	Description			
1	Digital OUT 1			
2				
3				
4	CAN high			
5	CAN low			
6	Battery +			
7	Battery -			
8				
9				
10	Digital IN 4			
11	Digital OUT 2			
12	MAG pickup			

How To Order

Part Number	Description	Notes
78700420	XM500 Murphy Standard*	Module
78700534	XM500 Configuration Tool	Tool
30000669	6' harness with terminating resistor	
30000685	6' harness without terminating resistor	Wire
30000670	12' harness with terminating resistor	Harness
30000686	12' harness without terminating resistor	

* To determine other configurations, review XM500 Config & Wiring documents.

Refer to www.murphybyenovationcontrols.com